

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7258-1483:165

Page 1 of 1

CATEGORY: Combination Ion/Photo Smoke Detector

LISTEE: Mirtone, 8985 Town Center Parkway, Bradenton, FL 34202
Contact: Jewell Micochero (941) 739-4358 FAX (941) 308-8123

DESIGN: Models GSA-IPHS and GSA-IPHSB combination ionization/photoelectric smoke detectors. Units have built in heat sensor. Refer to listee's data sheet for detailed model descriptions and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a combination ionization/photoelectric smoke detector for use with Edwards separately listed base (CSFM Listing No. 7300-1591:120) and compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

NOTE: NOT INTENDED TO BE USED IN LIEU OF REQUIRED HEAT DETECTORS.

XL: 7258-1591:123, Formerly 7258-1388:183

08-04-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 28, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division